

**GUJARAT STATE FERTILIZERS & CHEMICALS LTD  
FERTILIZERNAGAR**

Minutes of meeting with M/s Precise Engineers & M/s GSFC LTD. held on 5-12-2007  
For Replacement of 20" Exp. Joint of Co2 stripper Reboiler 910W3112) of Mel -I Plant.


**Ref:-Work order no Fert/M/Mel/Reg/6/07-08 dtd. 28-09-2007**

1. Work of Replacement of 20" Exp. Joint of Co2 stripper Reboiler (10W3112) has been carried out as per broad scope of work of above Work Order during shutdown period of Mel-I Plant ( from 30-11-2007 to 5-12-2007.)
2. D.P. test for all long seam & circumferential weld joints has been carried out & found ok.
3. Hydro test at 48.8 kg/cm<sup>2</sup> g is carried out as per requirement of GSFC and same has been witnessed by GSFC Engineer & M/s Precise Engineer representative & same found ok .

Shri Kartik Shastri

*S. Kartik Shastri*

**(For M/s Precise Engineer)**

  
5/12/07

Shri G.A. Patel (Sr. Mgr. -Mel-Maint.)

**G. A. PATEL**  
Sr. Manager (M) Melamine

*A.P.E 5/12/07*

Shri A.P. Vankar (Mel.-Maint.)

**A. P. VANKAR**  
MECHANICAL ENGINEER  
**(For GSFC LTD.)**  
MELAMINE